


NOTES:

1. BOLLARDS SHALL BE CONSTRUCTED OF STEEL NO LESS THAN 4-INCHES IN DIAMETER AND CONCRETE FILLED.
2. BOLLARDS SHALL BE SPACED NO MORE THAN 4-FEET BETWEEN POSTS ON CENTER.
3. BOLLARDS SHALL BE SET NO LESS THAN 3-FEET DEEP IN CONCRETE FOOTINGS OF NO LESS THAN A 15-INCH DIAMETER.
4. BOLLARDS SHALL BE SET WITH A TOP OF THE BOLLARDS NO LESS THAN 4-FEET ABOVE GROUND.
5. BOLLARDS TO BE LOCATED NO LESS THAN 3-FEET FROM THE PROTECTED OBJECT.

 <p>Silver Lake Water & Sewer District</p>	
<p>BOLLARD</p>	
<p>DATE: 12-2023</p>	<p>DWG: G12</p>