



NOTES:

1. REQUIRED FOR ACCESS TO FACILITIES PLACED IN VAULTS WHERE DEPTH FROM SURFACE TO FLOOR EXCEEDS 4 FEET.
2. VAULT SELECTION SIZED TO ALLOW CLEARANCE FOR PLACEMENT OF "SHIP LADDER"
3. SHIP LADDER TO BE GALVANIZED STEEL.
4. SHOP DRAWING APPROVAL OF SLWSD REQUIRED PRIOR TO INSTALLATION.
5. SHIPS LADDER MUST, AT A MINIMUM, ABIDE BY OSHA STANDARDS.
6. TREAD WIDTH SHALL BE MIN. 24" AND MIN. DEPTH OF 6".

SCALE: NTS

 <p>Silver Lake Water & Sewer District</p>	
<p>SHIPS LADDER</p>	
DATE: 11-2022	DWG: G4