



MINIMUM CASING DIAMETER	
CARRIER DIA.(IN.)	DIA.(IN.)
6	12
8	16
10	18
12	20
16	24

CASING SIZE MAY BE ADJUSTED WITH DISTRICT APPROVAL TO FIT AVAILABLE SPACER SIZE.

**NOTES:**

1. CONTRACTOR TO VERIFY LINE AND GRADE.
2. CARRIER PIPE WITHIN THE LENGTH OF THE ENCASEMENT PIPE SHALL HAVE RESTRAINED JOINTS.
3. REGULATORY AGENCY REQUIREMENTS SHALL SUPERSEDE DISTRICT STANDARDS IF MORE STRINGENT.
4. CASING PIPE SHALL BE SCHEDULE 40 STEEL PIPE, WELDED JOINT, AND MINIMUM YIELD STRENGTH (F) OF 35 KSI. SCALE: NTS



**Silver Lake Water & Sewer District**

**CASING AND CARRIER PIPES**

DATE: 11-2022

DWG: G5