


NOTES:

1. VAULT AND HATCH SHALL BE H20 RATED.
2. 2" COMBINATION AIR VALVE SHALL BE A STAINLESS STEEL ARI D-025 L AT A WORKING PRESSURE TO BE PROVIDED BY THE DISTRICT.

 <p>Silver Lake Water & Sewer District</p>	
<p>SEWER AIR VACUUM RELEASE VAULT</p>	
DATE: 11-2022	DWG: S10