


NOTES:

1. FOR SINGLE RESIDENTIAL/UNIT CONNECTION. ANY DEVIATION MUST BE REVIEWED AND APPROVED BY THE DISTRICT PRIOR TO INSTALLATION. ALL PIPE AND FITTINGS MUST BE INSTALLED PER DISTRICT STANDARDS.
2. 6" CLEANOUT IS REQUIRED FOR VISUAL INSPECTION OF THE PUMP LINE FLOW AND TO AID IN CLEANING OF THE SEWER SYSTEM. THE CLEANOUT MUST BE INSTALLED PER S16 PRIOR TO TESTING OF THE PUMP SYSTEM AND PERMIT SIGN-OFF.
3. FLEXIBLE COUPLINGS ARE NOT ALLOWED ON THE CONNECTION OF THIS SYSTEM.
4. PRESSURE PIPE SIZE AND TYPE TO BE PER PUMP MANUFACTURER RECOMMENDATIONS AND REQUIREMENTS OF THE CURRENT UNIFORM PLUMBING CODE.
5. INSTALL BURIED MARKER TAPE 1' ABOVE PRESSURE LINE. TAPE SHOULD READ "CAUTION BURIED SEWER BELOW".

 <p>Silver Lake Water & Sewer District</p>	
<p>PRESSURE LINE CONNECTION TO GRAVITY SEWER</p>	
DATE: 11-2022	DWG: S19