


NOTES:

1. COMPLY WITH ALL REGULATORY REQUIREMENTS OF JURISDICTIONAL AUTHORITY.
2. OUTLET PIPE SHALL BE OF EQUAL OR GREATER DIAMETER THAN THE INLET PIPE.
3. STRUCTURE, FRAME, AND COVER SHALL BE H-20 LOAD RATED IF LOCATED IN TRAFFIC AREA.

 <p><b>Silver Lake Water &amp; Sewer District</b></p>	
<p><b>SAMPLE CHAMBER FOR GREASE INTERCEPTOR &amp; OIL/WATER SEPARATOR</b></p>	
DATE: 11-2022	DWG: S22