



NOTES:

1. GRAVITY MAIN PIPE CONNECTIONS TO MANHOLES SHALL BE AS FOLLOWS: CORE THE MANHOLE AND CONNECT SEWER PIPE WITH A WATER TIGHT FLEXIBLE RUBBER BOOT IN MANHOLE WALL, KOR-N-SEAL BOOT OR EQUAL.
2. DROP OF GRADE THROUGH MANHOLE SHALL BE 0.10', UNLESS OTHERWISE NOTED.
3. ALIGN FORCE MAIN DISCHARGE AXIS WITH OUTLET PIPE WHEN FEASIBLE.
4. RESTRAIN FORCE MAIN JOINTS AND FITTINGS.
5. SEE STANDARD MANHOLE CALLOUTS ON S1.
6. CONCRETE ANCHOR BLOCK ONLY REQUIRED FOR HDPE FORCE MAINS.

 <p>Silver Lake Water & Sewer District</p>	
<p>FORCE MAIN DISCHARGE MANHOLE</p>	
DATE: 11-2022	DWG: S6