



NOTES:

1. 1" AIR VAC FOR WATER MAINS LESS THAN 12" AND 2" AIR VAC FOR WATER MAINS 12" OR LARGER.
2. ALL PIPING AND FITTINGS BETWEEN CORP AND INLET SIDE OF COMBINATION AIR AND VACUUM ASSEMBLY SHALL BE COPPER OR BRASS.
3. TAP WATER MAIN AT HIGH POINT AT LOCATION DESIGNATED BY THE DISTRICT.
4. AIR VAC ASSEMBLY TO BE CONNECTED USING HORIZONTALLY PLACED UNIONS AT EACH END OF AIR VAC ASSEMBLY (MATCH PIPE MATERIAL).
5. PAINT EXPOSED PORTION OF VENT PIPE AND MARKER POST WITH TWO COATS YELLOW PAINT, COLOR FORMULA TO BE PROVIDED BY DISTRICT.
6. 2' MINIMUM BURY REQUIRED ON MARKER POST.
7. MID STATES PLASTICS MSBCF 1730-12 COMPOSITE. BOX SHALL BE H-20 LOAD RATED WHERE REQUIRED.
8. FIELD LOCATION TO BE CONFIRMED WITH DISTRICT.

 <p>Silver Lake Water & Sewer District</p>	
<p>1-INCH COMBINATION AIR AND VACUUM RELEASE ASSEMBLY</p>	
DATE: 11-2022	DWG: W10