



- 1 MJ X MJ X 4" FL D.I. TEE.
- 2 4" AWWA RESILIENT SEAT GATE VALVE, FL X FL, WITH OPERATING NUT.
- 3 4" BLIND FLANGE, TAPPED FOR 2" FOR 6" AND 8" MAINS. MAINS LARGER THAN 8" SHALL END IN A FIRE HYDRANT.
- 4 CONCRETE THRUST BLOCK.
- 5 2" TYPE K COPPER OR BRASS PIPE.
- 6 CAST IRON VALVE BOX PER W4.
- 7 OLDCASTLE CARSON 1730-18 BCF HEAVYWALL METER BOX WITH COMPOSITE SOLID LID OR DISTRICT APPROVED ALTERNATE.
- 8 ALUMINUM CAM-LOCK AND CAP. DRILL 1/8" HOLE IN CAP. PLASTIC CAM LOCK FITTING NOT ALLOWED.

NOTES:

1. INSTALL DIELECTRIC COMPOUNDS FOR SEPARATION AT DISSIMILAR METALS.
2. FIELD LOCATION OF BLOW OFF AND METER BOX TO BE DETERMINED BY THE DISTRICT.



**Silver Lake Water & Sewer District**

**BLOW OFF ASSEMBLY**

DATE: 11-2022

DWG: W12