


- 1 1" DIRECT TAP
- 2 1" BALL TYPE CORPORATION STOP:
A. MUELLER B-25008-N.
B. FORD FB1000-Q4-NL.
C. A.Y. MCDONALD 74701BQ.
- 3 1" TYPE K COPPER SERVICE TUBING - LENGTH AS REQUIRED.
- 4 1"X1" WITH A 1" ANGLE METER BALL VALVE:
A. MUELLER B-24258-N.
B. FORD BA43-342-NL W2.
C. A.Y. MCDONALD 74642BQ.
REDUCER BUSHING FOR 5/8" METER TO BE INSTALLED BY DISTRICT AS NEEDED.
- 5 1" ANGLE DUAL CHECK VALVE TO BE SUPPLIED BY DISTRICT.
- 6 OLDCASTLE CARSON 1527-12 BCF HEAVYWALL METER BOX WITH COMPOSITE AMR LID OR DISTRICT APPROVED ALTERNATIVE.
- 7 AFTER TAPPING A DRY WATER MAIN, USE A MAGNET TO REMOVE SHAVINGS BEFORE INSTALLING THE CORPORATION STOP.

NOTES:

1. NO SPLICES IN 1" COPPER TUBING ALLOWED.
2. SERVICE FROM METER BOX TO HOUSE BY PROPERTY OWNER.
3. LEAD SERVICE LINES ARE PROHIBITED.
4. METER TO BE INSTALLED BY THE DISTRICT AT OWNER'S EXPENSE.
5. EASEMENT TO BE PROVIDED TO SLWSD AROUND METERS LOCATED OUTSIDE R/W.
6. SEE DISTRICT CODE CHAPTER 6.20, ARTICLE V, FOR CROSS CONNECTION CONTROL REQUIREMENTS.



Silver Lake Water & Sewer District

1-INCH WATER SERVICE

DATE: 11-2022	DWG: W13
---------------	----------