


NOTES:

1. NO SPLICES IN 2" COPPER PIPE ALLOWED.
2. SERVICE FROM METER BOX TO STRUCTURE BY PROPERTY OWNER.
3. INDIVIDUAL SERVICES REQUIRED FOR EACH STRUCTURE.
4. 2-INCH METER SETTER (WITH ADAPTERS IF 1 1/2-INCH METER USED). SETTER - A.Y. MCDONALD 730B7-WWFF 775 OR MUELLER B-2427N. DRILL 2" DIAMETER HOLE IN LID FOR AMR DEVICE.
5. OLDCASTLE CARSON 1730-12 BCF HEAVYWALL METER BOX WITH COMPOSITE AMR LID OR DISTRICT APPROVED ALTERNATIVE.
6. EASEMENT TO BE PROVIDED TO SLWSD AROUND METERS LOCATED OUTSIDE OF R/W.
7. SEE DISTRICT CODE CHAPTER 6.20, ARTICLE V, FOR CROSS CONNECTION CONTROL REQUIREMENTS.
8. METER TO BE INSTALLED BY THE DISTRICT AT OWNER'S EXPENSE. BYPASS TO BE LOCKED AND VISIBLE UNTIL ACCEPTED.
9. ALL SETTERS SHALL BE SET AT THE REQUIRED METER SPACING USING ALL THREAD OR OTHER MEANS.

SCALE: NTS

 <p>Silver Lake Water & Sewer District</p>	
<p>2-INCH WATER SERVICE</p>	
DATE: 11-2022	DWG: W14