


NOTES:

1. SAMPLE TAP ASSEMBLY MUST BE KUPFERLE X 94WM-ASSY OR DISTRICT APPROVED EQUAL.
2. 1" METER RESETER SHALL BE KUPFERLE 94-R-2 OR DISTRICT APPROVED EQUAL.
3. DISTRICT STAFF WILL INSTALL SAMPLE STATION WITH METER INSTALLATION.

SCALE: NTS

 <p>Silver Lake Water & Sewer District</p>	
<p>1 INCH WATER SAMPLE STATION</p>	
<p>DATE: 12-2023</p>	<p>DWG: W17B</p>