


NOTES:

1. 1'-6" FROM BACK OF SIDEWALK OR 3' FROM BACK OF CURB OR EDGE OF PAVEMENT.
2. PROVIDE MIN. 3'-0" CLEARANCE AND LEVEL AREA AROUND HYDRANT.
3. PAINT FIRE HYDRANT WITH TWO COATS YELLOW PAINT, COLOR FORMULA TO BE PROVIDED BY DISTRICT AND TOP OF HYDRANT COLOR DETERMINED BY SERVICE LEVEL GPM IN ACCORDANCE WITH FIRE MARSHALL REQUIREMENTS.
4. PAINT FOOTAGE TO VALVE WITH 2" HIGH BLACK LETTERS ON HYDRANT UNDER PORT FACING GV.
5. REMOVE ALL CHAINS FOR FIRE HYDRANT CAPS.
6. ACCEPTABLE HYDRANTS:
CLOW MEDALLION
MUELLER CENTURION
EAST JORDAN WATERMASTER 5CD250
WATEROUS PACER
7. INSTALL BLUE FIRE HYDRANT REFLECTOR. OFFSET 1 FOOT FROM ROAD CENTERLINE ON FIRE HYDRANT SIDE OF THE CENTERLINE.
8. VERTICAL EXTENSIONS NOT ALLOWED ON NEW CONSTRUCTION.
9. HYDRANTS NOT IN SERVICE SHALL BE COVERED UNTIL APPROVED FOR USE BY THE DISTRICT

SCALE: NTS

 <p>Silver Lake Water & Sewer District</p>	
<p>NEW FIRE HYDRANT ASSEMBLY</p>	
<p>DATE: 12-2023</p>	<p>DWG: W1</p>