


NOTES:

1. STAINLESS STEEL TAPPING TEE SHALL BE ROMAC, SMITH BLAIR, OR JCM INDUSTRIES MODEL NO. 432 OR 462.

O.D. RANGES (INCHES)	
6" - 6.59-6.99	
8" - 8.62-9.06	
12" - 12.90-13.30	FOR LARGER SIZES
16" - 17.15-17.55	CONSULT THE DISTRICT

2. TAP TO BE INSTALLED AT DEVELOPERS EXPENSE BY APPROVED TAPPING CONTRACTOR UNDER DISTRICT OBSERVATION.
3. TAPPING TEES SHALL BE AIR PRESSURE TESTED TO 100 PSI PRIOR TO TAPPING MAIN.
4. CONNECTIONS ONLY ALLOWED ON A NON HOLIDAY TUESDAY-THURSDAY UNLESS OTHERWISE APPROVED BY DISTRICT.
5. WET TAPS ARE NOT ALLOWED FOR SIZE ON SIZE CONNECTIONS TO CAST IRON PIPE; SHALL BE CUT-IN ONLY.



Silver Lake Water & Sewer District

WET TAP CONNECTION

DATE: 11-2022	DWG: W7
---------------	---------